

Project:	TR Řípov – V5580/5581
Conductor	Conductor
Designation:	243-AL1/39-ST1A, dia. 21,8 mm
Tension:	≤8,7 N/mm ²
Earth wire	Earth wire
Designation:	184-AL1/43-ST1A, dia. 19,5 mm
Tension:	≤8,2 N/mm ²
At the request of:	EGEM, s.r.o.
RIBE order number	2024_096

Index

1. Vibration damper types.....	1
2. Damper placement recommendation at tension clamps.....	2
3. Damper placement recommendation at suspension clamps	2
4. Damper placement recommendation at tension clamps.....	3
5. Damper placement recommendation at suspension clamps	3

1. Vibration damper types

Damper type 1 -

Damper type 2 -

Quantities (as per section „Damper distribution chart and quantities“):

	Conductor	Earth wire
Damper type	-	-
Total quantity	0	0

Richard Bergner

Elektroarmaturen GmbH & Co. KG

Registered office at Schwabach
Amtsgericht Nürnberg HRA 18054
Personally liable partner:
Richard Bergner Elektroarmaturen Verwaltungs GmbH
AG Nürnberg HRB 14827
USt-ID-Nr.: DE188368425
Steuernummer: 247/173/06704

www.ribe.de

Managing Directors:

Frank A. Bergner
Thomas Dann
Tolga Bayraktar

Address:

Norischstraße 24
91154 Roth
Germany

Telecommunication:

Phone +49 (0) 9122 / 87-0
Fax +49 (0) 9122 / 87-1506
E-Mail electrical-fittings@ribe.de

Bank Accounts:

Commerzbank Schwabach, Kto-Nr. 5 803 598, BLZ 760 400 61
SWIFT: COBA DE FF 760 IBAN: DE29 7604 0061 0580 3598 00
Deutsche Bank AG, Kto.Nr.: 750037400 BLZ: 76070012
SWIFT: DEUTDEMM760 IBAN: DE91 7607 0012 0750 0374 00

2. Damper placement recommendation at tension clamps

No dampers necessary.

1	Conductor	243-AL1/39-ST1A, dia. 21,8 mm
2	Tension clamp	B119020A07 ø20,30 - 22,50 S19
3	Vibration damper ID	-

3. Damper placement recommendation at suspension clamps

No dampers necessary.

1	Conductor	243-AL1/39-ST1A, dia. 21,8 mm
2	Suspension clamp	F03228A05KB ø21,72 - 22,67 S19
3	Vibration damper ID	-

4. Damper placement recommendation at tension clamps

No dampers necessary.

1	Conductor	184-AL1/43-ST1A, dia. 19,5 mm
2	Tension clamp	B119020A05 \varnothing 18,00 - 20,20 S19
3	Vibration damper ID	-

5. Damper placement recommendation at suspension clamps

No dampers necessary.

1	Conductor	184-AL1/43-ST1A, dia. 19,5 mm
2	Suspension clamp	F03228A02KB \varnothing 18,84 - 19,79 S19
3	Vibration damper ID	-